



SEE NOTE 4 FOR L-N (115V, 277V) APPLICATIONS

FIELD NOTES:

1. FIELD WIRING MUST BE COPPER CONDUCTOR, RATED AT 75°C MINIMUM.
2. PER NFPA70. TRANSFORMER IS FACTORY GROUNDED.
3. OPTIONAL ITEM. REFER TO ORDER ACKNOWLEDGMENT OR BUILD REPORT FOR OPTION REQUIREMENTS.
4. L-N (115V, 277V) APPLICATIONS USE SINGLE POLE FUSE BLOCK FOR L1 (BLK), NEUTRAL (WHT) TERMINATIONS ARE MADE AT LINE BLOCK (DISCONNECT).

LEGEND

	QUICK CONNECT, FEMALE
	QUICK CONNECT, MALE
	LEVER NUT
	CONTROL VOLTS WIRE
	LINE VOLTS WIRE
	WIRE HARNESS

UNCONTROLLED DOCUMENT WHEN PRINTED

THIS DRAWING MAY NOT REFLECT THE MOST CURRENT REVISION. PLEASE CHECK TO MAKE SURE DRAWING IS CURRENT.

THIS DRAWING CONTAINS PROPRIETARY DATA. UNAUTHORIZED DISCLOSURE REPRODUCTION, OR USE IS STRICTLY PROHIBITED WITHOUT WRITTEN PERMISSION.

REVISION DESCRIPTION		ZONE		SHEET METAL:		TITLE		MATERIAL		
SUBMITTAL RELEASE C				HOLE DIA ±0.005 CUT SIZE ±1" CUT ANGLE ±0.016 FORMED DIM ±0.031 FORMED ANGLE ±3° FORMED SQUARE ±0.031		WD, DDBC, 1PH, SELECT, 1M				
ECR/SQ/TRANSMITTAL NO.	DRAWN BY	DATE	CHECKED BY	DATE	DO NOT SCALE DRAWING DIMENSIONS ARE IN INCHES UNLESS OTHERWISE NOTED	SCALE	PART NO.	SHEET	DRAWING NO.	REV
ECR 3255	SJR	08/21/19	MSS	08/21/19	NTS	88-50000-18	18	88-50000	OC	